



DISABILITY AND COMMUNICATION ACCESS BOARD

919 Ala Moana Boulevard, Room 101 • Honolulu, Hawaii 96814
Ph. (808) 586-8121 (V/TDD) • Fax (808) 586-8129

INTERPRETIVE OPINION

Pursuant to §103-50, Hawaii Revised Statutes (HRS), all buildings and facilities constructed by, or on behalf of the State or any county, shall conform to the Americans with Disabilities Act Accessibility Guidelines (ADAAG) and amendments. In accordance to HRS §103-50 and Chapter 11-217, Hawaii Administrative Rules, the Disability and Communication Access Board has authority to issue interpretive opinions to HRS §103-50 design standards.

Docket: **DCAB 2005-07:** Is a non-opaque security barrier that is locked in the open position during a facility's hours of operation required to comply with the door requirements of the ADAAG, Section 4.13?

Ruling: For buildings or facilities subject to HRS §103-50,

ADAAG 4.13 Doors.

Security barriers that are locked in the open position during a facility's hours of operation are not required to comply with the door requirements of the ADAAG, Section 4.13.

[Rul: 9/05] (Auth and Imp: HRS §103-50)

If you have any questions or comments regarding this ruling, please call us at 586-8121.

DISABILITY AND COMMUNICATION ACCESS BOARD